

ABBREVIATIONS

AFT

80.0

CFM OR 5

CLO

CP

COND.

DA

DAMP

EF-1

ER

ELEV

F.C.

FD/AD

FSD-1

FSR

G.D.

M.E.R.

N.O.

NTS

R.A.

SPEC

SO

T.F.

TM

WWS

ABOVE FINISHED FLOOR

BOTTOM OF DUCT

CUBIC FEET PER MINUTE

CEILING

CONTROL PANEL

CONDENSATE

DAMPER

EXHAUST FAN (F)

ELEVATION

EXTERNAL STATIC PRESSURE

FLEXIBLE CONNECTION

FIRE DAMPER WITH ACCESS DOOR

FIRE SMOKE DAMPER (F)

FIRE/SMOKE RELAY

GRAVITY DAMPER

MECHANICAL EQUIPMENT ROOM

NECK CEILING DIFFUSER

NORMALLY OPEN

NOT TO SCALE

RETURN AIR

SPECIFICATION

SQUARE

TRANSFER FAN

THERMOSTAT MASTER

THERMOSTAT NUMBER

WIRE MESH SCREEN

SEQUENCE OF OPERATION

1. NORMAL OPERATION

EF-1 SHALL RUN CONTINUOUSLY TO MAINTAIN A NEGATIVE PRESSURE IN THE BATTERY ROOM. A DUCT MOUNTED AIR FLOW SWITCH UPON ACTIVATION (LOSS OF AIRFLOW), SHALL ACTIVATE A LOCAL HORN OUTSIDE THE BATTERY ROOM.

THE FAN IN THE AC UNIT SHALL RUN CONTINUOUSLY. A DUCT MOUNTED AIR FLOW SWITCH UPON ACTIVATION (LOSS OF AIRFLOW), SHALL ACTIVATE A LOCAL HORN OUTSIDE THE RADIO EQUIPMENT ROOM.

THE COOLING COIL OF THE AC UNIT SHALL BE CONTROLLED BY THERMOSTAT T1 (LOCATED IN THE RADIO EQUIPMENT ROOM) TO MAINTAIN THE ROOM TEMPERATURE SETTING.

2. ABNORMAL (HIGH TEMPERATURE) OPERATION

AS DESCRIBED ABOVE, AND:

IF THE TEMPERATURE IN THE RADIO EQUIPMENT ROOM EXCEEDS THE DESIRED MAXIMUM OF 75°F (ADJUSTABLE), THEN THERMOSTAT T3 SHALL ACTIVATE THE TRANSFER FAN TF-1 TO RUN, THIS MOVING AIR FROM THE MECHANICAL EQUIPMENT ROOM, THROUGH THE RADIO EQUIPMENT ROOM, INTO THE PLENUM.

SIMILARLY, IF THE TEMPERATURE IN THE BATTERY ROOM EXCEEDS THE DESIRED MAXIMUM OF 75°F (ADJUSTABLE), THEN THERMOSTAT T2 SHALL ACTIVATE THE EXHAUST FAN EF-2 TO RUN, THIS MOVING AIR FROM THE MECHANICAL EQUIPMENT ROOM, THROUGH THE BATTERY ROOM AND OUT OF THE BUILDING THROUGH ROOF.

3. SMOKE CONDITIONS

IF ANY OF THE THREE SMOKE DETECTORS (CEILING MOUNTED DETECTORS "SR" IN THE RADIO EQUIPMENT ROOM, "SB" IN THE BATTERY ROOM, OR THE AC UNIT'S SUPPLY AIR DUCT DETECTOR "D") SENSE SMOKE, THEN ALL FOUR FAN SHUTDOWN RELAYS FSR SHALL OPEN, THIS CUTTING POWER TO THE AC UNIT AND ALL FANS, AND CLOSING ALL MOTOR OPERATED DAMPERS (FIRE SMOKE DAMPERS) BETWEEN ROOMS (SEE "FIRE ALARM SYSTEM RISER DIAGRAM" ON DRAWING E-811.)

AN ALARM SIGNAL SHALL BE SENT THROUGH THE BUILDING'S FIRE ALARM SYSTEM, AND THREE LOCAL STROBE UNIT/ALARM SPEAKERS SHALL BE ACTIVATED.

IF CEILING MOUNTED DETECTOR "SR" IN THE RADIO EQUIPMENT ROOM OR THE AC UNIT'S SUPPLY AIR DUCT DETECTOR "D" SENSE SMOKE, THEN REMOTE ALARM INDICATOR "R" OR "D" RESPECTIVELY SHALL BECOME ENERGIZED.

IF CEILING MOUNTED DETECTOR "SB" IN THE BATTERY ROOM SENSES SMOKE, THEN REMOTE ALARM INDICATOR "B" SHALL BECOME ENERGIZED.

4. RETURN TO NORMAL OPERATION

BEFORE PUTTING AC UNIT BACK TO NORMAL OPERATION, THE FSD-1 TO FSD-5 SHALL BE MANUALLY RESET TO NORMALLY OPEN POSITIONS, AC UNIT SHALL BE MANUALLY RESTARTED (RESET) FROM THE FIRE CONTROL PANEL.

EQUIPMENT NOTES

1. FIRE SMOKE DAMPER (FSD-1, FSD-2, FSD-3, FSD-4, FSD-5), N.D.

FIRE SMOKE DAMPER SHALL BE A COMBINATION FIRE AND SMOKE DAMPER, FOR INSTALLATION IN 2 HOUR WALL, UL RATED FOR LEAKAGE CLASS 1 AND MEET NYC LOCAL CODE.

FRAME AND BLADES: 16 GAUGE GALVANIZED STEEL, 6" WIDE OPPOSED BLADES

UNWIND: CONCEALED INSIDE THE JAMB, 1/2" STEEL OPERATING SHAFT EXTENDING 4 1/2" FROM DAMPER SIDE.

SEALS: STAINLESS STEEL SIDE SEAL

FUSIBLE LINK: 165°F

FINISH: GALVANIZED

OPERATOR: 120 VOLT/1PH/60 HZ, ON/OFF, SPRING RETURN, WITH SPOT AUXILIARY SWITCH

DAMPER SIZE:

24" W X 30" H FSD-1 WITH OPERATOR MOTOR

24" W X 12" H FSD-2 WITH EXPLOSION PROOF OPERATOR

27" W X 27" H FSD-3 WITH OPERATOR MOTOR

12" W X 8" H FSD-4 WITH OPERATOR MOTOR

8" W X 8" H FSD-5 WITH OPERATOR MOTOR

FSD SHALL BE SAFE-AIR MODEL 772 WITH OPERATOR MOTOR OR APPROVED EQUAL

2. EXHAUST FAN (EF-1, EF-2)

THE FAN SHALL HAVE ANGLE SUPPORTS FASTENED TO THE CASING AND SPRING VIBRATION HANGERS FOR SUSPENSION FROM 3/8" DIA. ROD HANGERS. THE FAN SHALL HAVE AN INTEGRAL THERMAL OVERLOAD PROTECTION, A LOCAL DISCONNECT SWITCH AND A BACKDRAFT DAMPER.

3. TRANSFER FAN (TF-1)

THE FAN SHALL HAVE A BACKDRAFT DAMPER.

4. AIR-CONDITIONING UNIT (AC-1)

THE AC UNIT SHALL BE A SPLIT AIR CONDITIONING UNIT WITH DIRECT EXPANSION COOLING COIL AND AN AIR COOLED CONDENSING UNIT. THE AC UNIT SHALL HAVE THE FOLLOWING:

- WELDED STEEL FRAME

- 18 GAUGE, GALVANIZED OUTER CASING FINISHED IN ALUMINUM PAINT

- 2" THICK, 3 P.C.F. DENSITY ROD FIBER BOARD INSULATION

- 20 GAUGE GALVANIZED INNER CASING

- TWO OF 25 X 18, 2" THICK PLEATED TYPE FLAT FILTERS

- FOUR ROW 25 X 28 DX COOLING COIL WITH ALUMINUM FINS AND EXPANSION VALVE

- CENTRIFUGAL FC CURVE DHD BLOWER MOUNTED ON RAILING INSIDE THE CASING WITH VIBRATION ISOLATORS

- SPRING TYPE VIBRATION ISOLATORS

- MIXING BOX WITH 25X32 AND 12X8 DAMPERS

- EVAPORATOR DRAIN PAN SHALL BE STAINLESS STEEL CONSTRUCTION

- 1.5 HP FAN AS DESCRIBED IN AC UNIT SCHEDULE BELOW, WITH STARTER

AC UNIT SHALL BE HORIZONTAL INDOOR AIR HANDLER WITH ROOF MOUNTED AIR-COOLED CONDENSING UNIT.

5. THERMOSTATS

THERMOSTAT T1 FOR AC-1 UNIT, SHALL BE WALL MOUNTED, SINGLE STAGE, THERMOSTAT WITH SUBBASE, T1 SHALL BE A HONEYWELL MODEL 17300A WITH 07300B SUBBASE OR APPROVED EQUAL. THERMOSTAT T3 SHALL BE 120 VOLT, SPST, TO BE HONEYWELL MODEL T631C1103 OR APPROVED EQUAL.

THERMOSTAT T2 FOR THE BATTERY ROOM SHALL BE WALL MOUNTED, SINGLE STAGE, 3 WIRE SPDT, EXPLOSION PROOF FOR CLASS I, GROUP B HAZARDOUS LOCATION AND U.L. LISTED, AS MANUFACTURED BY: INTEL-THERM CORPORATION MODEL: OTS-4 OR APPROVED EQUAL. THERMOSTATS SHALL BE WALL MOUNTED AT 60" AFF UNLESS OTHERWISE NOTED.

6. EYE-WASH STATION (SELF-CONTAINED)

PROVIDE A WALL MOUNTED SELF-CONTAINED EYE-WASH STATION TO SUPPLY WATER FOR 15 MINUTES OF FLOW AT 0.4 GALLONS PER MINUTE. THE UNIT SHALL HAVE A TRANSPARENT 13.4 GALLON CONTAINER, HEAVY DUTY, WALL MOUNTED, TO BE BRADLEY MODEL S19-850A OR APPROVED EQUAL.

7. CONDENSATE PIPING

CONDENSATE PIPING SHALL BE TYPE L SEAMLESS COPPER TUBING, INSULATE WITH 1/2" THICK ARMAFLEX INSULATION AS MANUFACTURED BY ARMSTRONG WORLD INDUSTRIES OR APPROVED EQUAL. PROVIDE ADEQUATE PIPING HANGER SUPPORTS EVERY 6 FEET TO MEET NYC PLUMBING CODE (LATEST EDITION).

8. AIR FLOW SWITCH

AIR FLOW SWITCH SHALL BE DUCT MOUNTED TYPE, 120 VOLT A.C. WITH STAINLESS STEEL VANE, ADJUSTABLE VELOCITY RANGE, AND ONE (1) SPDT AUXILIARY SWITCH. IT SHALL BE DUYET MODEL NO. 450 OR APPROVED EQUAL.

9. CEILING DIFFUSERS AND EXHAUST REGISTERS

CEILING DIFFUSERS SHALL BE STAMPED TWO-POSITION ADJUSTABLE WITH VOLUME DAMPER AND DEFLECTOR, AS MANUFACTURED BY CARVES COMPANY INC. MODEL SFA 24X24 OR APPROVED EQUAL.

EXHAUST REGISTERS SHALL HAVE FIXED FACE BLADES WITH AN OPPOSED BLADE DAMPER, TO BE CARVES MODEL 500 OR APPROVED EQUAL.

10. SPRINKLER REPLACEMENT

REPLACE EXISTING SPRINKLERS (QUANTITY = 8) IN THE RADIO EQUIPMENT ROOM WITH SIMILAR SPRINKLERS BUT HIGHER TEMPERATURE RATING OF 282 DEGREE FAHRENHEIT. SPRINKLERS SHALL BE U.L. LISTED AND F.M. APPROVED AS MANUFACTURED BY STAR SPRINKLER CORP. MODEL E STANDARD UPRIGHT OR APPROVED EQUAL.

11. HORN

PROVIDE A LIGHTWEIGHT, COMPACT AUDIBLE SIGNAL DEVICE TO PRODUCE 110db AT 10 FEET WITH A WALL TYPE TONE SIGNAL, AS MANUFACTURED BY FEDERAL SIGNAL MODEL 3000C-120-TM1 OR APPROVED EQUAL.

12. REFRIGERATION PIPING

INSULATE JUNCTION PIPING AS PER SPECIFICATION SECTION 15945 ENTITLED "TYPIC INSULATION".

12. FIRE DAMPERS

FIRE DAMPERS SHALL HAVE A 1-1/2" HOUR FIRE RESISTANCE RATING IN ACCORDANCE WITH U.L. 555 AND MEET NYC LOCAL CODE.

DAMPER SIZE:

70" W X 45" H

72" W X 40" H

28" DIA.

FIRE DAMPER SHALL BE RATED FOR USE IN DYNAMIC SYSTEMS. BLADE MATERIAL: 24 GAUGE GALVANIZED STEEL, CURTAIN TYPE OUT OF AIR STREAM FOR MINIMUM FLOW AIR RESTRICTION.

FRAME MATERIAL: 4-7/8" WIDE, 20 GAUGE GALVANIZED STEEL CHANNEL.

CLOSURE SPRINGS: 301 STAINLESS STEEL

FUSIBLE LINK: 165°F

FIRE DAMPER SHALL BE RUSION MODEL D802, STYLE B OR APPROVED EQUAL. VERIFY DAMPER SIZES WITH ACTUAL EXISTING DUCT SIZES IN FIELD. COORDINATE SHUTDOWN OF AIR HANDLING UNITS WITH PORT AUTHORITY ENGINEER INCHARGE OF THE PROJECT.

| AC UNIT SCHEDULE | | | | | | | | | | | |
|--|------------------------|-------------------|--------------------|-------|-----|-----------------------------|--------|-----------------|-------|------------------------|-----------------------|
| UNIT # | TOTAL COOLING CAPACITY | SENSIBLE CAPACITY | EVAPORATOR SECTION | | | COMPRESSOR | | | POWER | MANUFACTURER AND MODEL | REMARKS |
| | | | CFM | ESP | HP | TYPE | NUMBER | TYPE | HP | | |
| AC-1 | 57,800 | 43,200 | 2000 | 0.50" | 1.5 | BACKWARD CURVED CENTRIFUGAL | 1 | HIGH EFFICIENCY | 5.0 | R-22 | 208/3/60 |
| BASED ON 95°F AMBIENT TEMPERATURE AT CONDENSER AND 78°F DB/64°F WB ENTERING AIR TEMPERATURE AT DX COIL. | | | | | | | | | | | |
| TENDROL AIR HANDLER, MODEL C12-42; APPLIED PRODUCTS CONDENSING UNIT, MODEL AAC-0550H2 OR APPROVED EQUAL. | | | | | | | | | | | LOW AMBIENT OPERATION |

| FAN SCHEDULE | | | | | | | | | | | |
|--------------|----------------------|------|------|---------------------------|-----|------|-------|-------------|------------------------|--|----------------------|
| FAN # | LOCATION | CFM | TSP | FAN TYPE | HP | RPM | POWER | | MANUFACTURER AND MODEL | REMARKS | |
| | | | | | | | VOLT | PHASE/HERTZ | | | |
| EF-1 | BATTERY ROOM | 165 | 1/4" | CENTRIFUGAL DIRECT DRIVEN | 1/4 | 873 | 115 | 1 | 80 | CARVES MODEL VXD0BL3 OR APPROVED EQUAL | SEE EQUIPMENT NOTE 2 |
| EF-2 | BATTERY ROOM | 300 | 3/8" | CENTRIFUGAL DIRECT DRIVEN | 1/4 | 1280 | 115 | 1 | 80 | CARVES MODEL VXD0BL2 OR APPROVED EQUAL | SEE EQUIPMENT NOTE 2 |
| TF-1 | RADIO EQUIPMENT ROOM | 3300 | 1/2" | PROPELLER DIRECT DRIVEN | 3/4 | 1725 | 208 | 3 | 80 | CARVES MODEL L08-118F3 OR APPROVED EQUAL | SEE EQUIPMENT NOTE 3 |